

Date	For	Sample Station 1	Sample Station 2	Sample Station 3	Sample Station 4	Sample Station 5	Sample Station 6	Sample Station 7	Sample Station 8	Before Treatment
		Behind Hotel	Earl Street near the school	Marble Bay Road @ Van Anda Ave	Smelter Road, across from Bob Gordon's	Sellentine Street @ Sturt Bay Road	Wall Street Pump house	Copper Queen Street @ Alladin	Storage Tank	Lake
2021 Dec 01	Coliform	L1	L1	L1	L1	L1	L1	L1	L1	193.5
	E. Coli	L1	L1	L1	L1	L1	L1	L1	L1	2.0
2022 Feb 09	<i>Transport issues caused samples to be unusable as not received within the 30 hour limit</i>									
2022 Feb 16	Coliform	L1	L1	L1	L1	L1	L1	L1	L1	16.8
	E. Coli	L1	L1	L1	L1	L1	L1	L1	L1	L1
2022 Mar 01	<i>Boil Water Notice issued from VAID as a precautionary measure after firefighting; lifted Mar 5 when test results received</i>									
2022 Mar 02	Coliform	L1	L1	L1	L1	L1	L1	L1	L1	34.1
	E. Coli	L1	L1	L1	L1	L1	L1	L1	L1	L1
2022 Apr 27	Coliform	L1	L1	L1	L1	L1	L1	L1	L1	32.7
	E. Coli	L1	L1	L1	L1	L1	L1	L1	L1	L1

L 1 = less-than-one (1) or zero (0)

A = Sample not tested, too long in transit

EST = High colony density preventing accurate count

G = Greater than

O/G = Overgrown with coliform present

B = More than 200 background colonies / 100 ml

D = Sample not tested; no collection date given

T = Sample submitted exceeded 30 hours holding time

Water Test Results