

Date	For	Sample Station 1	Sample Station 2	Sample Station 3	Sample Station 4	Sample Station 5	Sample Station 6	Sample Station 7	Sample Station 8	Sample Station 9	Sample Station 10	Before Treatment
		Behind Hotel	Earl Street near the school	Marble Bay Road @ Van Anda Ave	5124 Blewett	Sellentin Street @ Sturt Bay Road	Wall Street Pump house	Copper Queen Street @ Alladin	Storage Tank Outlet	Wall St end hydrant	Marble Bay Rd @ Sellentin	Lake
2025 Jun 24	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	1299.7
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1
2025 Jul 22	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	866.4
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	1.0
2025 Sep 09	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	686.7
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	2.0
2025 Oct 08	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	920.8
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	2.0
2025 Nov 05	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	51.2
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	1.0
2025 Dec 09	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	142.1
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	5.2
2026 Feb 02	Coliform	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	83.6
	E. Coli	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1	LT1

LT 1 = less-than-one (1) or zero (0)

A = Sample not tested, too long in transit

EST = High colony density preventing accurate count

G = Greater than

O/G = Overgrown with coliform present

B = More than 200 background colonies / 100 ml

D = Sample not tested; no collection date given

T = Sample submitted exceeded 30 hours holding time

LT1 GTR200 = something growing that's not Coliforms or E. coli. Usually low risk.

# Water Test Results